

21039

Control No.

STATE OF OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY

PERMIT NO.

30-21039

Fee

New Construction

Repair (Major)

Other

Permit Issued To

Paul & Penny Boyer-Larry Morgan BS

31

28

6400

Union, Wa

(Road Location)

(City)

(Issued by - Signature)

(Date Issued)

PERMITS ARE NOT TRANSFERABLE

ALL WORK TO CONFORM TO OREGON ADMINISTRATIVE RULES, CHAPTER 340. WORK SHALL BE DONE BY PROPERTY OWNER OR BY LICENSED SEWAGE DISPOSAL SERVICE. (MAKE NO CHANGES IN LOCATION OR SPECIFICATIONS WITHOUT WRITTEN APPROVAL)

SPECIFICATIONS

EXPIRATION DATE

12/29/89

TYPE OF SYSTEM

Standard

Design of Sewage Flow

450 Gal's/Day

Tank Volume

1000 Gallons

Disposal Trenches

2

Seepage Bed(s)

540 Square Feet

Maximum Depth

30 inches

Minimum Depth

24 inches

270 Linear Feet

Equal

Loop

Serial

Pressurized

Minimum Distance Between Trenches

10' on center with 2' wide trench

Total Rock Depth

12 inches

Below Pipe

6 inches

Above Pipe

2 inches

Rake Sidewall

Special Conditions (Follow Attached Plot Plan)

To be installed as per approved plan of 12/29/88. ON septic tank to be properly abandoned. Ground should be free of snow at PRE-COVER INSPECTION REQUIRED - CONTACT ERD-Pendleton (276-4063) time of installation

CERTIFICATE OF SATISFACTORY COMPLETION

As-Built Drawing with Reference Locations

Installer

Tresham

Final Insp. Date

4/20/89

Inspected By

CLC

Issued by Operation of Law

Pre-cover inspection waived pursuant to OAR 340, Division 71

Note: No vehicular or concentrated livestock use of drainfield/septic tank areas. Recommend installation of permanent barriers to surround areas. Note: septic tank should be pumped out periodically (every 4 to 5 yrs) by state licensed pumpier. Received As-Built 4/24/89 hand carried by Mike Tresham

In accordance with Oregon Revised Statute 454.665, this Certificate is issued as evidence of satisfactory completion of an on-site sewage disposal system at the location identified above.

Issuance of this Certificate does not constitute a warranty or guarantee that this on-site disposal system will function indefinitely without failure.

Authorized Signature

(Title)

(Date)

(Office)